

*RFI*

**To:** Paul J. Ingram  
Spreckels Memorial District  
90 Fifth Street  
Spreckels, CA 93962  
Ph: (831)455-7855

**RFI #:** PB-002  
**Date:** 2/3/2021  
**Job:** D21015 Spreckles Memorial Park ADA  
**Phone:**

**CC:**

**Subject:** Pre-Bid RFI #002 - Roofing Questions

**Drawing:**

**Spec Section:**

**Cost Impact:** TBD

**Schedule Impact:** TBD

**Request:**

**Date Required:** 2/12/2021

Plans says LtWt Slate over 30# felt, class "B" fire rating. The existing is a Concrete Slate tile that is no longer produced. Is the intention to use LtWt Slate style concrete tile over 2 layers of 30# felt and standard 1x2 wood battens? Please confirm

Standard hip and ridge trim, with detailing per Manufacturer?

Is a 24-gauge galvanized to be used on the new integral gutter added areas?

**Requested by:** Roxanne Cheysson

**Response:**

\_\_\_\_\_  
Answered By

\_\_\_\_\_  
Company

\_\_\_\_\_  
Date