



AUSONIO

11420A Commercial Parkway
Castroville, CA 95012
www.ausonio.com

Telephone (831) 633-3371
Upstairs Fax (831) 633-4004
Downstairs Fax (831) 633-3389

11420 A Commercial Parkway
Castroville, CA 95012
Ph : (831) 633-3371

RFI

To: Paul J. Ingram
Spreckels Memorial District
90 Fifth Street
Spreckels, CA 93962
Ph: (831)455-7855

RFI #: PB-014
Date: 2/19/2021
Job: D21015 Spreckles Memorial Park ADA
Phone:

CC:

Subject: Pre-Bid RFI #014 - Additional Door and Hardware Questions

Drawing:
Cost Impact: TBD

Spec Section:
Schedule Impact: TBD

Request:

Date Required: 2/26/2021

1. Do the new doors need louvers?
If required, please advise if the intent is to match existing.
If not, please provide specifications.
2. Is a hold open option desired? If so, please confirm which of the following is required :
 - Overhead stop with hold open (spring-loaded)
 - Wall stop with hold open (manual hook)
 - Floor stop with hold open (manual hook)
 - Wall hold open (spring-loaded)
 - Upgrade closer to have a hold-open arm
3. Please indicate what type of locks and/or keyway that the city uses; and if there is a (grand)master key system.

Requested by: Roxanne Cheysson

Response:

1. New doors do not have louvers.
2. No, special hardware is requested. Just accessible height handle and push plate similar to existing
3. Lock to be provided by owner.

Derek Johnson

Answered By
Central Coast Engineers, Inc.

Company

2/23/2021

Date



February 23, 2021

Spreckels Memorial Park
Restroom ADA Upgrade Project

To All Bidders:

Entry Door Clarifications:

1. Owner will provide Entry Door deadbolts to be installed by Lock and Key Provider at Owner's expense.
2. Door handle to be similar to existing.
3. Door closer to include hold-open arm.

Paul J. Ingram
General Manager