



RFI

To: Paul J. Ingram
Spreckels Memorial District
90 Fifth Street
Spreckels, CA 93962
Ph: (831)455-7855

RFI #: PB-001

Date: 2/3/2021

Job: D21015 Spreckles Memorial Park ADA

Phone:

CC:

Subject: Pre-Bid RFI #001 - Electrical Questions

Drawing:

Spec Section:

Cost Impact: TBD

Schedule Impact: TBD

Request:

Date Required: 2/12/2021

- 1- There is an existing sub panel located in the plumbing chase feeding all the circuits in the building. This sub panel is not shown on the drawings. Will we need to relocate this or provide a new sub panel?
- 2- There is no power shown for the hand dryers. Please provide circuit number and breaker size.
- 3- Does the new water heater require any power?
- 4- How will the exterior lights be controlled?
- 5- Are the A type fixtures surface mount or recessed?

Requested by: Roxanne Cheysson

Response:

1. Existing Main electrical meter and shut off to remain
 - a. New electrical sub panel
 - b. all new electrical inside building
2. & 3. Added panel schedule to plans
4. Added to plans
5. Revised plans to include corrected fixture. They are surface mounted

Derek Johnson

Answered By

2/11/2021

Central Coast Engineers, Inc

Company

Date