



AUSONIO

I N C O R P O R A T E D

11420A Commercial Parkway
Castroville, CA 95012
www.ausonio.com

Telephone (831) 633-3371
Upstairs Fax (831) 633-4004
Downstairs Fax (831) 633-3389

11420 A Commercial Parkway
Castroville, CA 95012
Ph : (831) 633-3371

Letter of Transmittal

To: Paul J. Ingram
Spreckels Memorial District
90 Fifth Street
Spreckels, CA 93962
Ph: (831)455-7855

Transmittal #: 003

Date: 2/9/2021

Job: D21015 Spreckles Memorial Park ADA

Subject: Pre-Bid RFI #013 - Power and Electrical Demo

WE ARE SENDING YOU

- ☐ Attached ☐ Under separate cover via the following items:
- ☐ Shop drawings ☐ Contract / PO ☐ Plans ☐ Samples
- ☐ LEED ☐ Change order ☐ Specifications ☒ RFI

Document Type	Copies	Date	No.	Description
RFI	1	2/9/21	PB-013	Pre-Bid RFI #013 - Power and Electrical Demo

THESE ARE TRANSMITTED as checked below:

- ☐ For approval ☐ Approved as submitted ☐ Resubmit ___ copies for approval
- ☐ For your use ☐ Approved as noted ☐ Submit ___ copies for distribution
- ☐ As requested ☐ Returned for corrections ☐ Return ___ corrected prints
- ☒ For review and comment ☐ Other
- ☐ FOR BIDS DUE ☐ PRINTS RETURNED AFTER LOAN TO US

Remarks:

Copy To:

From: Roxanne Cheysson (Ausonio Incorporated)

Signature:



AUSONIO

I N C O R P O R A T E D

11420A Commercial Parkway
Castroville, CA 95012
www.ausonio.com

Telephone (831) 633-3371
Upstairs Fax (831) 633-4004
Downstairs Fax (831) 633-3389

11420 A Commercial Parkway
Castroville, CA 95012
Ph : (831) 633-3371

RFI

To: Paul J. Ingram
Spreckels Memorial District
90 Fifth Street
Spreckels, CA 93962
Ph: (831)455-7855

RFI #: PB-013

Date: 2/9/2021

Job: D21015 Spreckles Memorial Park ADA

Phone:

CC:

Subject: Pre-Bid RFI #013 - Power and Electrical Demo

Drawing:

Spec Section:

Cost Impact: TBD

Schedule Impact: TBD

Request:

Date Required: 2/11/2021

1. Is power required to hand dyers, toilets, and urinals?
2. Plans do not state any electrical demo power with existing panel, lighting, and power - please advise.
3. Plans do not show any electrical demo of safe off - please advise.
4. There is an existing block wall where the hand dryers are to be installed, but power would need to be recessed in the wall per hand dryer specs. Please advise on how you would like us to proceed.

Requested by: Roxanne Cheysson

Response:

1. Power is required to hand dryer. Toilet and Urinals are battery operated. Revised plans.
2. Revised plans.
3. All interior electrical to be removed. Existing Main Shut off to remain.
4. Added core drill call out on plans.

Derek Johnson

Answered By

2/11/2021

Central Coast Engineers, Inc.

Company

Date